

TAGS	QTY	SUB	CATALOG	MFG	DESCRIPTION
AH3121	1		870P-NS	EDWARDS	Audio Indicator Electro-Mechanical Horn 120 VAC, NEMA 4, 4X
MSP1021	1	*1	140M-C2E-B63	AB	Motor Protector 140M Motor Protector 4.00 - 6.30 Amps
		*1	140M-C-AS411	Allen-Bradley	Motor Protector Accessory Auxiliary Contact 1 ND 1 NC CONTACTS
		*1	140M-C-FEC23	Allen-Bradley	Motor Protector Accessory Connecting Module 2SA
MSP1061	2	*1	140M-C2E-C10	AB	Motor Protector 140M Motor Protector 6.3 - 10.0 Amps
MSP1081		*1	140M-C-AS411	Allen-Bradley	Motor Protector Accessory Auxiliary Contact 1 ND 1 NC CONTACTS
		*1	140M-C-FEC23	Allen-Bradley	Motor Protector Accessory Connecting Module 2SA
CM4271	1		3-8850-1P	GF SIGNET	Monitor Cond/Res Monitor US, MS, KOhm, MOhm, PPM (TDS)
CC4081	1		3-8860-AC	GF SIGNET	Controller Cond/Res Controller US, MS, KOhm, MOhm, PPM (TDS)
RECP11511	4		HBL5252	HUBBELL	Receptacle Duplex Outlet, 2-Pole, 3-Wire 15A, 125VAC/DC
RECP11531					
RECP11551					
RECP11621	1		2832085	PHENIX CONTACT	5 Port Ethernet Switch FL-SWITCH-STX Ethernet Switch 5 Port Unmanaged
CR1131	1		700-CF400D	AB	RELAY - TYPE CF SEALED 4 POLE 600V MAX AC 120 AC, 60 Hz COIL 4 ND, 0 NC CONTACTS
CR3051	5	*1	RH2B-ULC AC120	IDEC	RELAY - MIDGET 300V MAX AC 120 AC, 50/60 Hz COIL 2 NO CONTACTS (TOTAL: 2 NO-2 NC)
CR3061					
CR3071					
CR3081					
CR3091					
ADJ1251	2		20AD8P0A3AVNNNNN	AB	RELAY - SDDCKET 300V MAX AC
ADJ1381					
DS1001	2		194R-NU060P3	AB	Fused Disconnect IEC Fused Disconnect Switch 60A Class J
DS1001	1	*1	194R-NU060P3	AB	Fused Disconnect IEC Fused Disconnect Switch 60A Class J
		*1	194R-HS4E	Allen-Bradley	Operating Handle IEC Disconnect Switch Handle
		*1	194R-R2	Allen-Bradley	Operating Shaft IEC Fused Disconnect Switch Shaft
		*3	LPJ-40SP	BUSSMANN	DUAL ELEMENT FUSE, TIME DELAY CLASS J, Low-Peak, Dual-Element 600 VAC 40 AMP
ENC1241	1	*1	A48H3612GRPLP	HOFFMAN	Enclosure 48X36X12 Enclosure Nema 4X
		*1	A-48P36	Hoffman	Enclosure Accessory 48X36 Enclosure Panel
FT4021	2		3-8550-1P	GF SIGNET	Flow Transmitter Flow Transmitter Panel Mount Nema 4X
FT4341					
FUJ131	1	*1	LP-CC-1	BUSSMANN	CURRENT-LIMITING, TIME-DELAY CLASS CC, CURRENT-LIMITING, TIME-DELAY 600 VAC 1 AMP
		*1	BC6031P	BUSSMANN	FUSE HOLDER 600 VAC 1 POLE, CLASS CC (FNO-R, 1/4 - 30 AMP)
FUJ141	2	*1	LP-CC-10	BUSSMANN	CURRENT-LIMITING, TIME-DELAY CLASS CC, CURRENT-LIMITING, TIME-DELAY 600 VAC 10 AMP
FUJ2011					
		*1	BC6031P	BUSSMANN	FUSE HOLDER 600 VAC 1 POLE, CLASS CC (FNO-R, 1/4 - 30 AMP)
FUJ191	2	*1	LP-CC-15	BUSSMANN	CURRENT-LIMITING, TIME-DELAY CLASS CC, CURRENT-LIMITING, TIME-DELAY 600 VAC 15 AMP
FUJ211					
		*1	BC6031P	BUSSMANN	FUSE HOLDER 600 VAC 1 POLE, CLASS CC (FNO-R, 1/4 - 30 AMP)
FUJ101	1	*2	LP-CC-15	BUSSMANN	CURRENT-LIMITING, TIME-DELAY CLASS CC, CURRENT-LIMITING, TIME-DELAY 600 VAC 15 AMP
		*1	BC6032P	BUSSMANN	FUSE HOLDER 600 VAC 2 POLE, CLASS CC (FNO-R, 1/4 - 30 AMP)
FUJ581	2	*1	LP-CC-2	BUSSMANN	CURRENT-LIMITING, TIME-DELAY CLASS CC, CURRENT-LIMITING, TIME-DELAY 600 VAC 2 AMP
FUJ601					

TAGS	QTY	SUB	CATALOG	MFG	DESCRIPTION
FUJ121	1	*1	LPJ-50SP	BUSSMANN	DUAL ELEMENT FUSE, TIME DELAY CLASS J, Low-Peak, Dual-Element 600 VAC 5 AMP
		*1	J60060-1C	BUSSMANN	FUSE HOLDER 600 VAC 1 POLE, CLASS CC (FNO-R, 1/4 - 30 AMP)
HM12081	1		271P-16C20A	ALLEN-BRADLEY	PVPUS600 Color Touch Touch Panel 4x Color 120 VAC
LT1591	7		HW1P-1F0D-G-120	IDEC	GREEN PILOT LIGHT 22.5mm 120 AC FULL VOLTAGE
LT1611					
LT2911					
LT5311					
LT6311					
LT8341					
LT1311	1		HW1P-1F0D-W-120	IDEC	WHITE PILOT LIGHT 22.5mm 120 AC Full Voltage
LT2011	1		HW1P-1F0D-R-120	IDEC	RED LED PILOT LIGHT, IP65 NEMA 1/2/3/3R/3S/4/4X/5/12/13 22.5mm 120 AC FULL VOLT
M1161	5		100-C12D10	AB	IEC CONTACTOR, AC 3 POWER POLES NON-REVERSING 12AMP, 110VAC LINE SIDE
M1171					
M1181					
M1201					
M1221					
PB2661	1		HW1B-ME1P10-B	IDEC	PUSH BUTTON - MOMENTARY, IP65 NEMA 1/2/3/3R/3S/4/4X/5/12/13 22.5mm EXTENDED BLACK IND
PB1131	1		HW1B-V4F01-R	IDEC	PUSH BUTTON - TWIST RELEASE MUSHROOM 22.5mm RED 40mm MUSHROOM INC
PBL1131	1		HW1L-ME1110D-R-120	IDEC	ILLUMINATED PUSH BUTTON - MOMENTARY, IP66 NEMA 4/4X/13 22.5mm EXTENDED RED EXT IND-INC 120 AC FULL VOLT
PLC2041	1		1747-L591	ALLEN-BRADLEY	PLC Processor SLC 5/05 16K Memory ENET, RS-232
PLC2261	2		1746-1A16	AB	PLC DIGITAL I/O MODULE 16 POINT RELAY OUTPUT 15A @ 120V AC, N.D. CONTACTS
PLC5511					
PLC3261	1		1746-N18	AB	PLC ANALOG I/O MODULE 8 CHANNEL ANALOG INPUT PLC ANALOG I/O MODULE 4 ANALOG OUTPUTS (0-20mA) 14 BIT RESOLUTION
PLC3511	1		1746-ND41	AB	PLC DIGITAL I/O MODULE 16 POINT RELAY OUTPUT 15A @ 120V AC, N.D. CONTACTS
PLC3011	1		1746-DV16	AB	PLC DIGITAL I/O MODULE 16 POINT RELAY OUTPUT 15A @ 120V AC, N.D. CONTACTS
PS2021	1	*1	1746-P2	ALLEN-BRADLEY	PLC Power Supply SLC/1746 System 120/220 VAC 70W
PS2211	1		PS3R-E24	IDEC	DC Power Supply Switching DC Power Supply 24VDC, 4.2A, 100-240VAC, 50/60Hz
SS2511	1		HW1K-2AF10	IDEC	SELECTOR SW - 2 POS MAINT, IP65 NEMA 2.3,3R,4,4X,12,13 22.5mm KEY (L-R) IND
SS2521	8		HW1S-31F20	IDEC	SELECTOR SW - 3 POS, IP65 NEMA 1/2/3/3R/3S/4/4X/5/12/13 22.5mm BLACK LEVER 2 ND
SS2531					
SS2541					
SS2551					
SS2561					
SS2571					
SS2581					
SS2591					
TS1	23		0115 116.07	ENTRELEC	Ground Lug GROUND TERMINAL #6-#14 Cu-AL
TS2					
TS1	2		0165 113.16	ENTRELEC	TERMINAL BLOCK FEED-THROUGH 26 Amp
CB12051	2		9953K24	MCMMASTER	Data Transition Patch Cord Category SE, 2xRJ45 5ft+, EIA/TIA 568-B Wiring Pattern UL Listed, Yellow Jacket
CB12121					
XF1111	1		HSSF5AS	SDLA/HEAVY-DUTY	JP Transformer Transformer General Purpose Transformer 5000VA, 230x460 VP, 120 VS Wall Mount

NOTES:

ATTENTION: Only qualified technical personnel familiar with the construction and operation of this equipment and the hazards involved, should install, adjust, operate and/or service this equipment. Read and understand the instruction manual in its entirety before proceeding. Failure to observe this precaution could result in equipment damage and/or severe bodily injury or loss of life.

NO.	DATE	DESCRIPTION	BY
-	-	-	-
-	-	First Issue	-

ESTIMATED WEIGHT	SERVICE REQ.
SHIPPING	480VAC, 3Ø, 60Hz
OPERATING	PNEUMATIC
	WATER


CUSTOMER: Atlantic Constructors, Inc.
Rodi Water System

ENG. BY: JDB
DWN. BY: JDB

SCALE: 1016536
APP. BY:

TITLE: RODI Water Purification System

DWG NO.: 1016536EL
REV.: A



BURT PROCESS
EQUIPMENT

FLUID HANDLING EQUIPMENT SINCE 1970
1050 SHERMAN AVE. HANDEE, CT 06514 (203) 287-1985
WWW.BURTPROCESS.COM