



The College of
WILLIAM & MARY



2014 ANNUAL CAMPUS FIRE SAFETY REPORT

FIRE SAFETY REPORT

Introduction

The health and safety of faculty, staff, students, and visitors to the campus of the College of William & Mary is of paramount importance to everyone. It directly impacts both the quality and value of the university. Each person and every department is expected to perform work in a safe and healthy manner and in compliance with the regulatory requirements.

Overview

The Higher Education Opportunity Act (HEOA) became public law in August 2008. This law mandates all institutions of higher education that provide residential housing facilities for students to develop an annual fire safety report. The contents of this report reflect the requirements that are outlined in the HEOA, which state that the college will maintain a fire log and report fire statistics to the Secretary of the Department of Education. The majority of the required fire safety report data can be located in The College of William & Mary Fire and Life Safety Program document. The Fire and Life Safety Program contains policies and procedures that, when implemented and maintained, will satisfy the International Fire Code (IFC) (2009 Ed.), the Virginia Statewide Fire Prevention Code (VSFPC) (2009 Ed.), the Virginia Uniform Statewide Uniform Building Code (VUSBC) (2009 Ed.), legal obligations, help satisfy insurance requirements, prevent loss of life, injury and property damage due to fire and other emergencies.

Fire Prevention Inspections

Fire prevention starts with identifying fire hazards. All members of our college community, faculty, staff, students and visitors have a personal obligation to be aware of fire hazards and to reduce or eliminate the risk of fire on our campus. Annual inspections are conducted at each residence hall on campus by the State of Virginia Fire Marshal's Office. Any deficiencies that are found by the State Fire Marshal are entered into the Corrective Action Tracking System (CATS) and tracked to closure by the College Fire Safety Officer. The facilities maintenance teams also alert the Fire Safety Officer of any occupant activities that place occupants at risk. CATS is a database management tool developed by the College of William & Mary Office of Environmental Health and Safety. Deficiencies are documented, categorized and prioritized by the CATS database. In addition, our facilities maintenance teams conduct monthly walk through inspections of their assigned residence halls to identify and correct facilities management fire and life safety issues. Work orders to correct the deficiencies are issued to the appropriate facilities management section for completion. Items of a prohibitive nature are removed by those individuals who introduced such items, and are educated on those areas from which the observation was made.

Fire Protection System Communications

All resident hall fire protection systems located on the campus of The College of William & Mary signal directly to the Campus Police Department or, a monitoring agency in leased buildings for emergency response. Central communications for the college is located in a secure area with the Campus Police Department Headquarters. The central communications office is staffed with highly trained personnel. Central communications is an essential department that is staffed 24 hours a day, 7 days a week, 365 days a year. However, when an alarm is seen or heard an emergency call to 911 should be placed to ensure that accurate emergency information is communicated. Building occupants are directed to observe the locations of emergency exits, exit signs, fire alarm system pull stations, and portable fire extinguishers. All of the aforementioned item locations are denoted on the building evacuation maps.

Fire Safety Policies for College Dormitory Residents

1. OPEN FLAMES (from any source) and burning materials of any kind are absolutely prohibited in the residence halls.
2. The integrity of all ceilings, floors and walls must remain intact and not be disturbed. Also, light fixtures must have proper globe or deflector in place. Any open bulb fixtures are a fire hazard and should be reported.
3. Additional wall coverings (e.g. paneling, wallpaper, etc.) cannot be installed by occupants.
4. In reference to VSFPC section 308.4.1; Candles, incense and similar open-flame producing devices are prohibited in residence halls, even if such items are unlit or being used only for decorative purpose only.
5. In reference to VSFPC section 807.1.2; No more than 10% of a residence hall room's wall surface area may be covered by potentially flammable objects. This includes but is not limited to posters, framed pictures, photos, flags, tapestries or any other decorative objects that are mounted on the wall. Residents in residence hall rooms that approach or surpass this 10% level may be required to remove items as necessary to comply with state fire safety requirements. In addition, wall hangings cannot contact electrical outlets or come closer than 12 inches to the heating unit. All ceiling decorations are prohibited.
6. In reference to chapter 8 of the VSFPC window decorations other than college furnished shades, drapes or blinds may be used but must carry a recognized fire rating and be constructed of fire retardant material.
7. Living areas must be kept uncluttered and access to the doors clear. Hallways and stairways must remain clear and unobstructed.
8. At no time may the maximum capacity restrictions of a room, apartment, or lodge be exceeded.

9. Residents may make use of the working fireplaces in the following areas after receiving training on fireplace safety given by the College Fire Safety Officer: DuPont Hall, Graduate Complex building 800 Lounge, Sororities (with the exception of the 2nd floor fireplace located in Sorority House 1), Lodges 4-16, Tazewell Hall and Taliaferro Hall.
 - a. Fires in fireplaces should never be unattended.
 - b. There should always be a fire extinguisher present in the vicinity when there is an attended fire in the fireplace.
 - c. The use of chemical fire starters is prohibited.

Prohibited Items in the Residence Halls

Some examples of items not permitted in the residence halls are listed here; however, this list is not necessarily all inclusive: animals (excluding fish and therapy/ service animals), non-fused extension cords, outside antennas, bread machines, candles, incense, ceiling fans, chain locks, crock pots, dead-bolt locks, explosives, firearms, fireworks, gasoline and other combustible liquids, hot pots that are not thermostatically controlled, immersion coils, incense, oil lamps, open flames, space heaters, torchere-style (pole) halogen lamps, waterbeds and weapons. Live cut Christmas trees, as mandated by the State fire code, are not permitted in the residence halls.

Prohibited Items in Student Rooms

The following appliances are prohibited in student rooms, but may be used in residence hall kitchens: hot plates, toaster ovens, broilers, electric skillets/woks and other portable electric cooking devices.

Allowable Appliances in Student Rooms

The following appliances are allowed to be used in student rooms: refrigerators that are no greater than 4.3 cubic feet, hot air popcorn poppers, thermostatically controlled hot pots and coffee pots, and microwave ovens without a convection option. All allowable appliances must be plugged directly into a wall receptacle, be Underwriter Laboratories (UL) listed and be in proper working order and condition.

Electrical Safety

1. Permanent electrical circuits cannot be altered by occupants or anyone not authorized by the College.
2. Appliances, lamps and other electrical equipment with damaged, worn, cracked, or frayed cords and plugs must be replaced.

3. All lighting fixtures must use only light bulbs of type and wattage as recommended by the manufacturer. Lamp shades must also meet manufacturer specifications for the specific fixture.
4. Electrical cords or other communication cables may not be installed under carpets, hung over nails or run through doorways and windows.
5. The following are prohibited in residence hall rooms: multi-plug adapters (the type that are affixed directly to the wall outlet), cube adapters, unfused plug strips or items such as air fresheners that include an outlet on them.
6. Grounded relocatable power taps or surge protector strips with heavy duty cords and a “reset” switch will be the only allowable receptacle extensions from wall outlets. Each power tap will be connected directly into a wall receptacle and they shall not be plugged into one another.
7. Non-fused extension cords and flexible cords are prohibited in Residence Hall rooms.
8. No power cord, of any type, shall be extended through walls, ceilings or floors, or under doors or floor coverings, nor shall any cord be subject to environmental damage or physical impact.
9. Any cord that has physical damage or splicing must immediately be removed from service and removed from residence halls.

Smoking Policy

Complying with the requirements of the Commonwealth of Virginia, all residence halls, apartments, and houses are smoke-free. Residents and their guests must refrain from smoking at any time they are physically present in the building, including in private residence rooms and within twenty five (25) feet of any building entrance or exit.

Transient Quarters

During summer months The College of William & Mary offers many of their residence halls to be used by a multitude of youth academic and athletic camps. Coaches, group leaders, and/or supervisors are responsible for providing instruction to youth participants on fire evacuation procedures at the beginning of their stay. When our facilities are being utilized by campers we take some additional precautions in order to ensure a safe and pleasant visit to our campus. Buildings are strategically selected based on their proximity to the Williamsburg Fire Department (WFD) and ease of access for response. The WFD is located 2 minutes off campus. Building Emergency Plans (BEP) are updated and posted prior to building occupation. Building evacuation maps are posted in each building on every floor, and a copy is provided to all campers. The muster point for each building is 100 feet from the front of the building.



Emergency Evacuation/Fire Drills

Emergency Evacuation Drills (also referred to as Fire Drills) are a vital part of a comprehensive campus fire safety program. Emergency Evacuation/Fire Drills are held to familiarize occupants with drill procedures and to make the organized building exit a matter of established routine.

The Virginia Statewide Fire Prevention Code (VSFPC) Section 405.1 through 405.9 and 408.3 through 408.3.4 state that a minimum of four (4) Emergency Evacuation/Fire Drills must be conducted in each R-2 classified occupancy group (College and University Dormitories) annually. Furthermore, at least one (1) drill must be performed after sunset and before sunrise. The College of William & Mary meets this annual requirement by performing one (1) drill at the beginning of the fall and spring semesters as well as one (1) drill at the beginning of the first and second summer sessions. At least one of these aforementioned drills is performed in the evening. Emergency Evacuation/Fire Drills at The College of William & Mary are unannounced and preplanned. Students and staff are educated to understand that if a fire alarm sounds they should take immediate action by raising the alarm vocally, closing doors, report the fire by calling 911 and evacuating the building to a predestinated “muster area” located one hundred (100) feet from each building. During a drill, the Fire Safety Officer (FSO) provides a five to ten (5-10) minute “tool box” training session with the staff and students at the muster points as part of our drill protocol. Additionally, smoke house fire safety training, fire portable extinguisher training, and a further detailed Fire Safety Lecture are provided to all resident assistants (RA’s) during their induction as house staff at the beginning of the academic year before the students arrive and move in.

Many of the buildings referred to in this report have a Knox-Box System installed on the exterior of the structure near the main entrance. A Knox-Box is a high-security key box system, designed to give firefighters and emergency services immediate access to locked buildings, elevators, and other secured areas. At The College of William & Mary Knox Boxes contain access keys, critical information about the building, its fire protection systems, as well as information concerning the special needs of any impaired occupants housed within. This information is updated at the beginning of each school semester. Only the City of Williamsburg Fire Department, The W&M Police Department and the department of Environmental Health & Safety Office have access to these Knox Boxes in the event of an emergency. The Knox-Box System is designed for maximum protection; each virtually indestructible box features a special high-security Medeco lock and key. This Medeco restricted locking system guards against unauthorized key duplication. Keys are not available to locksmiths or lock distributors, only The Knox Company can supply these keys.

In accordance with the VSFPC section 404.3.1 all university owned buildings have fire evacuation plan placards posted throughout the building. Fire evacuation plans (also referred to

as building evacuation maps) denote the emergency egress or escape routes and muster point locations. If any changes are made in any building due to refurbishment or new construction that alter the path of egress, the fire evacuation plan placards as a condition of occupancy certification by the AHJ and are updated prior to the admittance of any occupants.

The Office of Environmental Health and Safety (EH&S) tracks and trends all false fire alarm calls that occur on campus in an effort to determine what training and inspection efforts are priority in order to reduce the highest trend areas and improve campus fire safety.

Future Improvements

The following data reflects information provided in the Fire Safety Systems Summary section.

Proposed FY 2013 Improvements:

Sorority House 1 (Kappa Kappa Gamma) Fire Alarm System upgrade to include software and new Fire alarm Control Panel.

Proposed FY 2014 Improvements:

Mumford Hall (Dillard Complex) Fire Alarm Panel upgrade to include software.

Chandler Hall Renovation includes Fire Alarm Panel upgrade to include software.

Graduate Complex Building 500 Sprinkler upgrade and Fire Alarm Panel upgrade to include software.

Fire & Life Safety Education Programs

AED—The College of William & Mary currently maintains an Automated External Defibrillator Program (AED). This program utilizes employees who serve as trained responders in cardiopulmonary resuscitation (CPR) and AED therapy in the event of medical emergency. Sixty-three (63) AED's have been strategically in buildings placed throughout the campus in order to provide a reduction in response time to life threatening emergencies. Fifteen (15) of the 63 AED's are located in residence halls. Our Student Assembly completed a study in 2007 to determine AED location placement at distances taking no more than three (3) minutes to retrieve any AED unit from the area of the emergency. The WFD provides emergency medical response that includes basic and advanced life support, CPR, and emergency cardiac care. The goal of the AED program is to participate actively in the Chain of Survival. The chain of survival includes early access; early CPR; early defibrillation; and early advanced care.

Fire Extinguishers—Due to the large number of portable fire extinguishers on campus (approximately nineteen hundred) (1900) The College of William & Mary instituted a bar code tracking system for all of its portable fire extinguishers. This new tracking system ensures that



the College fully meets the requirements set forth in the National Fire Protection Association (NFPA) standard ten (10) in regards to inspection, placement and maintenance of our portable fire extinguishers. Additionally, classes are taught each year to students (at the request of their RA's and clubs), faculty and staff as to the proper use of portable fire extinguishers. Classes are also taught to research students in our science program. The P.A.S.S. method (pull; aim; squeeze; sweep) is our preferred method for small fire extinguishment using portable extinguishers. We augment instruction with hands on training utilizing the "live fire" Bull-Ex fire training simulator. Each August we train approximately one hundred (100) resident assistants in fire safety practices and conclude with hands on portable fire extinguisher training.

Fire Alarm Log—The College of William & Mary maintains a detailed fire alarm log which is available by contacting the Office of Environmental Health and Safety (EH&S). The following information is a compilation of fires that occurred on campus during the 2013 HEOA Fire Safety Reporting period:

Date: **Time:** **Location:** **Value Range:** **Dispatch Summary:**

No fires occurred on campus during the 2013 HEOA Fire Safety Reporting period.

Fire Reporting Contact (Non-Emergency)

The College of William & Mary is required to annually enclose statistical data on all fires that occur in on-campus student housing facilities. Listed below are the non-emergency numbers to call concerning a fire that has been already been extinguished in on-campus housing. These are fires for which you are unsure whether the College of William & Mary Environmental, Health and Safety Office may already be aware of. If you find evidence of such a fire or if you hear of such a fire, please contact one of the following:

Environment Health and Safety Office:

Sandra Prior, Director: 757-221-2146

Steve Singleton, Senior Safety Engineer: 757-221-2288

Bradley Meirs, Fire Safety Officer: 757-221-1745

Facilities Maintenance:

Work Control: 757-221-2270

William & Mary Police Dispatcher: 757-221-4596



Questions, comments, or concerns pertaining to this report may be directed to:

Bradley T. Meirs, Fire Safety Officer
Dept. of Facilities Management, Environmental, Health, & Safety Office
208 S. Boundary Street, Williamsburg, VA 23185
Desk 757-221-1745, Cell 757-645-8657, Email: btmeirs@wm.edu
The College of William & Mary, www.wm.edu
[back](#)

Annual Statistics

Fire Safety Systems Summary (Residence Halls)								
Location	# of Beds	Disabled Resident Rooms	Supervised Fire Alarm System	Sprinkler System	Manual Pull Stations	Stand Alone Smoke Detectors	Partial Heat Detectors	Stand Pipe System
Barrett Hall	90	Yes/2	YES	NO	YES	YES	YES	NO
Brown	40	NONE	YES	NO	YES	YES	YES	NO
Bryan Hall	58	NONE	YES	PARTIAL	YES	YES	YES	NO
Cabell Hall	28	NONE	YES	PARTIAL	YES	YES	YES	NO
Camm Hall	34	NONE	YES	NO	YES	YES	YES	NO
Chandler	72	Yes/1	YES	NO	YES	YES	YES	NO
Dawson Hall	26	NONE	YES	NO	YES	YES	YES	NO
Dinwiddie Hall	23	Yes/1	YES	NO	YES	YES	YES	NO
DuPont Hall	140	NONE	YES	NO	YES	YES	YES	NO
Fraternity House 620 Kappa Sigma	17	ALL	YES	YES	YES	YES	YES	NO
Fraternity House 630 Kappa Alpha	17	ALL	YES	YES	YES	YES	YES	NO
Fraternity House 640 Alpha Tau Omega	17	ALL	YES	YES	YES	YES	YES	NO
Fraternity House 660 Delta Chi	17	ALL	YES	YES	YES	YES	YES	NO
Fraternity House 670 Sigma Pi	17	ALL	YES	YES	YES	YES	YES	NO
Fraternity House 710 Sigma Alpha Epsilon	17	ALL	YES	YES	YES	YES	YES	NO
Fraternity House 720 Pi Kappa Alpha	17	ALL	YES	YES	YES	YES	YES	NO
Fraternity House 730 Delta Phi	17	ALL	YES	YES	YES	YES	YES	NO
Fraternity House 740 Beta Theta Pi	17	ALL	YES	YES	YES	YES	YES	NO
Fraternity House 750 Kappa Delta Rho	17	ALL	YES	YES	YES	YES	YES	NO
Fraternity House 760 Sigma Phi Epsilon	17	ALL	YES	YES	YES	YES	YES	NO
Fauquier Hall	46	Yes/2-3	YES	NO	YES	YES	YES	NO
Griffin A-E	95	NONE	YES	NO	YES	YES	YES	NO
Eagle F-J (no I)	76	NONE	YES	NO	YES	YES	YES	NO
Lions K-M	57	NONE	YES	NO	YES	YES	YES	NO
Giles Hall	36	NONE	YES	PARTIAL	YES	YES	YES	YES
Gooch Hall	46	Yes/2-3	YES	NO	YES	YES	YES	NO
Graduate Housing Bldg 100	24	NONE	YES	YES	YES	YES	YES	NO
Graduate Housing Bldg 200	35	NONE	YES	YES	YES	YES	YES	NO
Graduate Housing Bldg 300	34	NONE	YES	YES	YES	YES	YES	NO
Graduate Housing Bldg 400	24	NONE	YES	YES	YES	NO	YES	NO
Graduate Housing Bldg 500	12	NONE	YES	YES	YES	NO	YES	NO
Graduate Housing Bldg 600	34	NONE	YES	YES	YES	YES	YES	NO
Graduate Housing Bldg 700	32	NONE	YES	YES	YES	YES	YES	NO
Graduate Housing Bldg 800	12	NONE	YES	YES	YES	YES	YES	NO
Graduate Housing Bldg 900	12	NONE	YES	YES	YES	YES	YES	NO
Harrison Hall	24	NONE	YES	PARTIAL	YES	YES	YES	YES
Hunt Hall	36	NONE	YES	YES	YES	YES	YES	NO
Jamestown North	204	YES	YES	YES	YES	NO	NO	YES
Jamestown South	183	YES	YES	YES	YES	NO	NO	YES
Jefferson Hall	99	YES/4	YES	YES	YES	YES	YES	YES
Landrum Hall	108	NONE	YES	NO	YES	YES	YES	NO
Lodge 4	3	NONE	YES	NO	YES	YES	YES	NO
Lodge 6	3	NONE	YES	NO	YES	YES	YES	NO
Lodge 8	3	NONE	YES	NO	YES	YES	YES	NO
Lodge 10	3	NONE	YES	NO	YES	YES	YES	NO
Lodge 12	3	NONE	YES	NO	YES	YES	YES	NO



Fire Safety Systems Summary (Residence Halls)

Location	# of Beds	Disabled Resident Rooms	Supervised Fire Alarm System	Sprinkler System	Manual Pull Stations	Stand Alone Smoke Detectors	Partial Heat Detectors	Stand Pipe System
Lodge 14	3	NONE	YES	NO	YES	YES	YES	NO
Lodge 16	3	NONE	YES	NO	YES	YES	YES	NO
Ludwell 100	52	N/A	YES	NO	YES	YES	YES	NO
Ludwell 200	52	N/A	YES	NO	YES	YES	YES	NO
Ludwell 300	52	N/A	YES	NO	YES	YES	YES	NO
Ludwell 400	52	N/A	YES	NO	YES	YES	YES	NO
Ludwell 500	52	N/A	YES	NO	YES	YES	YES	NO
Ludwell 600	52	N/A	YES	NO	YES	YES	YES	NO
Ludwell 700	53	N/A	YES	NO	YES	YES	YES	NO
Madison Hall	35	NONE	YES	NO	YES	YES	YES	NO
Monroe Hall	71	NONE	YES	PARTIAL	YES	YES	YES	NO
Nicholas	18	Yes/1	YES	YES	YES	YES	YES	YES
Nicholson	46	NONE	YES	NO	YES	YES	YES	NO
Old Dominion Hall	85	NONE	YES	NO	YES	YES	YES	NO
One Tribe Place	326	4	YES	YES	YES	YES	YES	YES
Page Hall	16	NONE	YES	NO	YES	YES	NO	YES
Pleasants	39	NONE	YES	NO	YES	YES	YES	YES
Reves Hall	27	NONE	YES	YES	YES	NO	YES	NO
Sorority #1 - Kappa Kappa Gamma	9	NONE	YES	NO	YES	YES	NO	NO
Sorority #2 - Alpha Chi Omega	7	NONE	YES	NO	YES	YES	NO	NO
Sorority #3 - Chi Omega	7	NONE	YES	NO	YES	YES	YES	NO
Sorority #4 - Delta Delta Delta	8	NONE	YES	NO	YES	YES	YES	NO
Sorority #5 - Pi Beta Phi	7	NONE	YES	NO	YES	YES	YES	NO
Sorority #6 - Kappa Delta	7	NONE	YES	NO	YES	YES	YES	NO
Sorority #7 - Delta Gamma	10	NONE	YES	NO	YES	YES	YES	NO
Sorority #8 - Phi Mu	8	NONE	YES	NO	YES	YES	YES	NO
Sorority #9 - Kappa Alpha Theta	8	NONE	YES	NO	YES	YES	YES	NO
Sorority #10 - Delta Sigma Theta	4	NONE	YES	NO	YES	YES	YES	NO
Sorority # 11 - Gamma Phi Beta	6	NONE	YES	NO	YES	YES	YES	NO
Sorority # 12 - Delta Phi	5	NONE	YES	NO	YES	YES	YES	NO
Spotswood Hall	46	Yes/2-3	YES	NO	YES	YES	YES	NO
Stith Hall	35	NONE	YES	NO	YES	YES	YES	NO
Taliaferro Hall	28	NONE	YES	NO	YES	YES	YES	N
Tazewell Hall	1	NONE	YES	NO	YES	YES	NO	N
Yates Hall	134	NONE	YES	NO	YES	YES	YES	N
William Randolph Lodge	2	NONE	NO	NO	NO	YES	NO	YES
Tribe Square	52	YES/4	YES	YES	YES	YES	YES	YES



Fire Safety Summary (Residence Halls)

Location	Knox Box	Evacuation Plans Posted	Fire Extinguisher Inspections	AED	CO Detectors	Fire Drills Completed*	Designated Evacuation Muster Area	Reported Fires 2011	Reported Fires 2012	Reported Fires 2013
Barrett Hall	YES	YES	12/12	YES	NONE	2	YES	0	0	0
Brown	NO	YES	12/12	YES	NONE	2	YES	0	0	0
Bryan Hall	YES	YES	12/12	YES	NONE	4	YES	0	0	0
Cabell Hall	NO	YES	12/12	NO	Yes/7	4	YES	0	0	0
Camm Hall	YES	YES	12/12	NO	NONE	2	YES	0	0	0
Chandler	YES	YES	12/12	YES	NONE	2	YES	0	0	0
Dawson Hall	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Dinwiddie Hall	NO	YES	12/12	NO	NONE	2	YES	0	0	0
DuPont Hall	YES	YES	12/12	YES	Yes/9	2	YES	1	0	0
Fauquier Hall	NO	YES	12/12	YES	Yes/7	2	YES	1	0	0
Fraternity House 620 Kappa Sigma	YES	YES	12/12	YES	Yes/1	2	YES	N/A	N/A	0
Fraternity House 630 Kappa Alpha	YES	YES	12/12	YES	Yes/1	2	YES	N/A	N/A	0
Fraternity House 640 Alpha Tau Omega	YES	YES	12/12	YES	Yes/1	2	YES	N/A	N/A	0
Fraternity House 660 Delta Chi	YES	YES	12/12	YES	Yes/1	2	YES	N/A	N/A	0
Fraternity House 670 Sigma Pi	YES	YES	12/12	YES	Yes/1	2	YES	N/A	N/A	0
Fraternity House 710 Sigma Alpha Epsilon	YES	YES	12/12	YES	Yes/1	2	YES	N/A	N/A	0
Fraternity House 720 Pi Kappa Alpha	YES	YES	12/12	YES	Yes/1	2	YES	N/A	N/A	0
Fraternity House 730 Delta Phi	YES	YES	12/12	YES	Yes/1	2	YES	N/A	N/A	0
Fraternity House 740 Beta Theta Pi	YES	YES	12/12	YES	Yes/1	2	YES	N/A	N/A	0
Fraternity House 750 Kappa Delta Rho	YES	YES	12/12	YES	Yes/1	2	YES	N/A	N/A	0
Griffin A-E	YES	YES	12/12	YES	Yes/4	2	YES	0	0	0
Eagle F-J (no I)	YES	YES	12/12	NO	Yes/4	2	YES	0	0	0
Lion K-M	YES	YES	12/12	YES	Yes/4	2	YES	0	0	0
Giles Hall	NO	YES	12/12	NO	NONE	4	YES	0	0	0
Gooch Hall	NO	YES	12/12	NO	Yes/7	2	YES	0	0	0
Graduate Housing Bldg 100	NO	YES	12/12	NO	Yes/1	2	YES	0	0	0
Graduate Housing Bldg 200	YES	YES	12/12	NO	NONE	2	YES	0	0	0
Graduate Housing Bldg 300	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Graduate Housing Bldg 400	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Graduate Housing Bldg 500	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Graduate Housing Bldg 600	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Graduate Housing Bldg 700	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Graduate Housing Bldg 800	NO	YES	12/12	YES	Yes/1	2	YES	0	0	0
Graduate Housing Bldg 900	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Harrison Hall	NO	YES	12/12	NO	NONE	4	YES	0	0	0
Hunt Hall	YES	YES	12/12	NO	NONE	2	YES	0	0	0
Jamestown North	YES	YES	12/12	YES	Yes/13	4	YES	1	0	0
Jamestown South	YES	YES	12/12	YES	NONE	4	YES	0	0	0
Jefferson Hall	YES	YES	12/12	YES	NONE	2	YES	0	0	0
Landrum Hall	YES	YES	12/12	YES	NONE	4	YES	0	0	0
Lodge 4	NO	YES	12/12	NO	YES/1	4	YES	0	0	0
Lodge 6	NO	YES	12/12	NO	YES/1	4	YES	0	0	0



Fire Safety Summary (Residence Halls)

Location	Knox Box	Evacuation Plans Posted	Fire Extinguisher Inspections	AED	CO Detectors	Fire Drills Completed*	Designated Evacuation Muster Area	Reported Fires 2011	Reported Fires 2012	Reported Fires 2013
Lodge 8	NO	YES	12/12	NO	YES/1	4	YES	0	0	0
Lodge 10	NO	YES	12/12	NO	YES/1	4	YES	0	0	0
Lodge 12	NO	YES	12/12	NO	YES/1	4	YES	0	0	0
Lodge 14	NO	YES	12/12	NO	YES/1	4	YES	0	0	0
Lodge 16	NO	YES	12/12	NO	YES/1	4	YES	0	0	0
Ludwell 100	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Ludwell 200	NO	YES	12/12	NO	NONE	2	YES	1	0	0
Ludwell 300	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Ludwell 400	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Ludwell 500	NO	YES	12/12	NO	Yes/2	2	YES	0	1	0
Ludwell 600	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Ludwell 700	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Madison Hall	YES	YES	12/12	NO	NONE	2	YES	0	0	0
Monroe Hall	YES	YES	12/12	YES	NONE	2	YES	0	0	0
Nicholas	NO	YES	12/12	NO	NONE	4	YES	0	0	0
Nicholson	NO	YES	12/12	YES	NONE	2	YES	0	0	0
Old Dominion Hall	YES	YES	12/12	YES	NONE	4	YES	0	0	0
One Tribe Place	YES	YES	12/12	YES	NONE	2	YES	N/A	N/A	0
Page Hall	NO	YES	12/12	NO	NONE	4	YES	0	0	0
Pleasants	YES	YES	12/12	NO	NONE	4	YES	0	0	0
Reves Hall	NO	YES	12/12	YES	NONE	2	YES	0	0	0
Sorority #1 - Kappa Kappa Gamma	NO	YES	12/12	NO	Yes/2	2	YES	0	0	0
Sorority #2 - Alpha Chi Omega	NO	YES	12/12	NO	Yes/3	2	YES	0	0	0
Sorority #3 - Chi Omega	NO	YES	12/12	NO	Yes/3	2	YES	0	0	0
Sorority #4 - Delta Delta Delta	NO	YES	12/12	NO	Yes/4	2	YES	0	0	0
Sorority #5 - Pi Beta Phi	NO	YES	12/12	NO	Yes/3	2	YES	0	0	0
Sorority #6 - Kappa Delta	NO	YES	12/12	NO	Yes/3	2	YES	0	0	0
Sorority #7 - Delta Gamma	NO	YES	12/12	NO	Yes/3	2	YES	0	0	0
Sorority #8 - Phi Mu	NO	YES	12/12	NO	Yes/3	2	YES	0	0	0
Sorority #9 - Kappa Alpha Theta	NO	YES	12/12	NO	Yes/4	2	YES	0	0	0
Sorority #10 - Delta Sigma Theta	NO	YES	12/12	NO	Yes/4	2	YES	0	0	0
Sorority # 11 - Gamma Phi Beta	NO	YES	12/12	NO	Yes/4	2	YES	0	0	0
Sorority # 12 - Delta Phi	NO	YES	12/12	NO	Yes/3	2	YES	0	0	0
Spotswood Hall	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Stith Hall	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Taliaferro Hall	NO	YES	12/12	NO	Yes/2	2	YES	0	0	0
Tazewell Hall	NO	YES	12/12	YES	Yes/1	2	YES	0	0	0
Yates Hall	YES	YES	12/12	YES	NONE	2	YES	0	0	0
William Randolph Lodge	NO	YES	12/12	NO	NONE	2	YES	0	0	0
Tribe Square	YES	YES	12/12	NO	NONE	2	YES	0	0	0

* Residence Halls indicating only 2 fire drills completed were not occupied by students during the summer sessions.



DISSEMINATION OF THIS REPORT

The Annual Campus and Fire Safety Report is distributed as an electronic link to all active William & Mary email accounts of students and employees, including faculty and staff. The report is also posted in a public location on the institutions [Compliance & Policy website](#).

Prospective employees are notified of the availability of the report via a direct link URL on the <https://jobs.wm.edu> where all employment applications must be submitted. Prospective students are notified of the availability of the report via a direct link URL after submitting a request for more information with their personal contact information. Graduate prospective students receive notification on the create account and/or login page for the respective graduate school application.

Current or prospective students and employees may request a paper copy at no charge from the Office of Compliance & Policy, James Blair Hall, Suite 101, Williamsburg, Virginia, 23185, or by calling 757-221-3146.